



32

**BRUHAT BANGLORE MAHANAGARA PALIKE**  
**YELAHANKA ZONE**

Office of the Assistant Director of Town Planning, Yelahanka Zone, Amruthahalli main road,  
Bangalore-560092

No.ADTP/JC(Y.N)/O.C/LP/564/2018-19

Date:19-01-2021

**OCCUPANCY CERTIFICATE**

**Sub:** Issue of Occupancy Certificate for Residential Apartment building at Katha No 688/6/5B & 6/5C, Samigehalli ward no 05, Jakkur Bengaluru.

**Ref:** 1. Plan sanction issued by this office vide LP no Ad.Com/YLK/564/2018-19 Dt.26-02-2019  
2. Your Application Dated:18-12-2020  
3. Approval of Joint Commissioner, Yelahanka Zone, Dated:22-12-2020,  
\*\*\*

The building Plan was sanctioned by this office vide LP no Ad.Com/YLK/564/2018-19 Dt.26-02-2019 for construction of Residential Apartment building at Katha No 688/6/5B & 6/5C, Samigehalli ward no 05, Jakkur , Bengaluru. consisting of Stilt+GF+FF+SF+TF+ Terrace floor. The Commencement Certificate was obtained on 04-06-2019

The building was inspected for issue of Occupancy certificate. During the inspection, it is observed that there is deviation in construction with reference to the sanctioned plan, which is within the permissible limits of regularization and the same has been regularized with a levy of Compounding fee. The compounding fee for occupancy certificate works out to Rs.8,64,400/- (Eight Lake Sixty four Thousand Four hundred rupees only). The same has been paid by the applicant in the form of D.D No. 024112 Dated: 28-12-2020 drawn from Axis Bank Ltd Bangalore and taken to BBMP account vide receipt No.RE-ifms223-TP/00090, Dated: 19-01-2021. The deviations effected by the applicant are regularized.

Permission is hereby granted to occupy of Residential Apartment building at Katha No 688/6/5B & 6/5C, Samigehalli ward no 05, Jakkur, Bengaluru. consisting of Stilt+GF+FF+SF+TF+ Terrace floor. with the following details.

| Sl. No | Floors Descriptions   | BUA Area (in Sqm) | Remarks   |
|--------|-----------------------|-------------------|---|
| 1      | Stilt Floor           | 1889.12 Sqm       | Should be Used for 82 Car Parking. Including 3 Lift and 3 Staircase. & Ramp.        |
| 2      | Ground floor          | 1985.12 Sqm       | Should be Used For 18 Residential Dwelling Units Including. 3 Lifts. & 3 Staircase. |
| 3      | 1st Floor             | 1985.12 Sqm       | Should be Used For 18 Residential Dwelling Units Including. 3 Lifts. & 3 Staircase. |
| 4      | 2st floor             | 1985.12 Sqm       | Should be Used For 18 Residential Dwelling Units Including. 3 Lifts. & 3 Staircase. |
| 5      | 3 <sup>rd</sup> floor | 1985.12 Sqm       | Should be Used For 18 Residential Dwelling Units Including. 3 Lifts. & 3 Staircase. |
| 6      | Terrace floor         | 68.59 Sqm         | Lift, Staircase head Room & OHT,  |
| 7      | Total                 | 9898.19 Sqm       |   |
| 8      | FAR                   | 2.13              | 2.13<2.25   |
| 9      | Coverage              | 53.01%            | 53.01<55%. within sanction limit  |

*[Signature]*  
Assistant Director Of Town Planning (Yelahanka)


### Subject to the following conditions

1. The car parking at Stilt Floor shall have adequate safety measures. It shall be done entirely at the risk and cost of owner and BBMP will not be responsible for any kind of damage, losses, risks, etc., arising out of the same.
2. Facility for physically Handicapped persons prescribed in schedule 11 (Bye law-31) of building bye-laws 2003 shall be ensured.
3. The structural safety of building will be entirely at the risk and cost of owner/Architect/structural Engineer and BBMP will not be responsible for the structural safety.
4. The Owner/Applicant shall not add/alter materially, the Structure or a part of the structure there off without specific permission of BBMP. In the Event of the Applicant Violating, the BBMP has the right to demolish the deviated /altered/added portion without any prior notice.
5. Rain water harvesting structure shall be maintained in good condition for storage of water for non potable purpose or recharge of ground water at all times as per building bye-laws 2003 clause No.32 (B).
6. Since, Deviation has been done with respect to the sanctioned plan, while constructing the building, hence the security deposit is here with forfeited.
7. The Applicant shall plant trees in the premises and maintain the same in good condition.
8. Owner shall make his own arrangements to dispose the debris/Garbage after segregating it in to organic and in organic waste generated from the building. Suitable arrangements shall be made by the owner himself to transport and dump these segregated wastes in consultation with the BBMP Zonal health Officer.
9. In case of any false information, misrepresentation of facts, or pending court cases, the occupancy certificate shall be deemed to be cancelled.
10. Arrangements like fire extinguisher and facilities to be provided in the building and maintained properly. For any untoward incident in case of fire, BBMP is not responsible in any way and solely the owner will be held responsible for any loss of life or damage to public property.
11. Safety to electrical installations, transformer is the entire responsibility of the owner. Any untoward incident that may cause out of electrical installations or transformer, the BBMP shall not be responsible in any way. The electrical installation should not be altered as the alteration/extra tapping of power may cause short circuit that may lead to hazard. The applicant/owner is solely responsible & BBMP is in no way responsible for this.
12. It is instructed to make own provision for treatment of waste generated (Including Solid waste, wet waste and Liquid waste) within premises as per Karnataka State Pollution Control Board Norms

On default of the above conditions, the Occupancy Certificate issued will be withdrawn without any prior notice.

To,

M/s Navanaami Projects Pvt Ltd  
Katha Katha No 688/6/5B & 6/5C,  
Samigehalli, ward no 05,  
Jakkur Bengaluru

  
Assistant Director of Town Planning (Yelahanka)  
Bruhat Bangalore Mahanagara Palike  
Yelahanka Zone.

19/1/21